


2491B / 6701B – H05Z-K / H07Z-K EN 50525-3-41 Cable

Cable Flexible

CJDL Cable



➤ APPLICATION

LSZH panel wiring for appliances with maximum operating temperatures of 90° C, and generally in areas (such as public and government buildings) where smoke and toxic fumes may cause a threat to life and equipment. The cables produce no corrosive gases when burnt which is particularly important where electronic equipment is installed.

➤ STANDARDS

EN 50525-3-41, EN 60228,
Flame Retardant according to IEC/EN 60332-1-2,
IEC/EN 60332-3-24
Halogen Free according to IEC/EN 61034-1/2,
IEC/EN 60754-1/2

➤ CHARACTERISTICS

Voltage Rating (Uo/U)

H05Z-K - 0.5mm² to 1mm²: 300/500V

H07Z-K - 1.5mm² to 240mm²: 450/750V

Temperature Rating

-25° C to +90° C

Minimum Bending Radius

Up to 35mm²: 4 x overall diameter

50mm² and above: 6 x overall diameter

➤ CABLE LABORATORY

We have state-of-the-art laboratory facilities and cutting-edge testing equipment, supported by a strict quality control protocol throughout the entire production process. Every production batch undergoes comprehensive technical tests prior to shipment. Only products that meet the most stringent quality standards are approved for distribution. This ensures our products deliver outstanding stability, reliability and durability, fully complying with customers' technical specifications and requirements.

➤ CONSTRUCTION

Conductor

Class 5 flexible copper conductor

Insulation

LSZH (Low Smoke Zero Halogen)

➤ DEDICATION TO SUSTAINABILITY

At CJDL Cable, we are fully committed to ecological transition and environmental protection. We actively push forward decarbonization goals, steadily moving toward a zero-emission business model.

To this end, we keep pursuing technological innovation to improve energy efficiency and cut pollutant emissions. Meanwhile, we optimize manufacturing processes to reduce environmental impact, securing sound, responsible and sustainable long-term growth for the company.

➤ CABLE THIRD-PARTY ACCREDITATION

We supply BASEC approved products

Cables are tested and certified by BASEC, The British Approvals Service for Cables

DIMENSIONS

NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL THICKNESS OF INSULATION mm	NOMINAL OVERALL DIAMETER mm		MINIMUM RESISTANCE OF INSULATION AT 90° C Mohms/km	NOMINAL WEIGHT kg/km
		Lower Limit	Upper Limit		
0.5	0.6	2.1	2.6	0.015	8.7
0.75	0.6	2.2	2.8	0.011	11.3
1	0.6	2.4	2.9	0.01	13.9
1.5	0.7	2.8	3.5	0.010	19.3
2.5	0.8	3.4	4.3	0.009	30.9
4	0.8	3.9	4.9	0.007	44.9
6	0.8	4.4	5.5	0.006	64.2
10	1	5.7	7.1	0.0056	108.2
16	1	6.7	8.4	0.0046	163.4
25	1.2	8.4	10.6	0.0044	248.1
35	1.2	9.7	12.1	0.0038	340.6
50	1.4	11.5	14.4	0.0037	484.2
70	1.4	13.2	16.6	0.0032	671
95	1.6	15.1	18.8	0.0032	895.8
120	1.6	16.7	20.9	0.0029	1111.1
150	1.8	18.6	23.3	0.0029	1389.2
185	2	20.6	25.8	0.0029	1724.1
240	2.2	23.5	29.4	0.0028	2225.4

COLOUR CODES

COLOUR	Black	Blue	Grey	Green/Yellow	Orange	Red	Pink	Yellow	Violet	Brown	White
CODE	BK	BL	GR	GY	OR	RD	PK	YW	VI	BR	WH

CONDUCTORS

Class 5 Flexible Copper Conductors for Single Core and Multi-Core Cables

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM DIAMETER OF WIRES IN CONDUCTOR mm	MAXIMUM RESISTANCE OF CONDUCTOR AT 20° C ohms/km
		Plain Wires
0.5	0.21	39
0.75	0.21	26
1	0.21	19.5
1.5	0.26	13.3
2.5	0.26	7.98
4	0.31	4.95
6	0.31	3.3
10	0.41	1.91
16	0.41	1.21
25	0.41	0.78
35	0.41	0.554
50	0.41	0.386
70	0.51	0.272
95	0.51	0.206
120	0.51	0.161

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM DIAMETER OF WIRES IN CONDUCTOR mm	MAXIMUM RESISTANCE OF CONDUCTOR AT 20° C ohms/km
		Plain Wires
150	0.51	0.129
185	0.51	0.106
240	0.51	0.0801

The above table is in accordance with EN 60228

ELECTRICAL CHARACTERISTICS

Current Carrying Capacity and Voltage Drop

NOMINAL CROSS SECTIONAL AREA mm ²	REFERENCE METHOD A (ENCLOSED IN CONDUIT IN THERMALLY INSULATING WALL ETC) Amps		REFERENCE METHOD B (ENCLOSED IN CONDUIT ON A WALL OR IN A TRUNKING ETC) Amps		REFERENCE METHOD C (CLIPPED DIRECT) Amps		REFERENCE METHOD F (IN FREE AIR OR ON A PERFORATED CABLE TRAY ETC HORIZONTAL OR VERTICAL ETC) TOUCHING Amps			REFERENCE METHOD G (IN FREE AIR) SPACED BY ONE CABLE DIAMETER Amps	
	2 Cables Single- Phase AC or DC	3 or 4 Cables Three- Phase AC	2 Cables Single- Phase AC or DC	3 or 4 Cables Three- Phase AC	2 Cables Single- Phase AC or DC flat or touching	3 or 4 Cables Three- Phase AC flat and touching or trefoil	2 Cables Single- Phase AC or DC flat	3 Cables Three- Phase AC flat	3 Cables Three- Phase AC trefoil	2 Cables Single-Phase AC or DC or 3 Cables Three-Phase AC flat	
										Horizontal	Vertical
1	14	13	17	15	19	17.5	-	-	-	-	-
1.5	19	17	23	20	25	23	-	-	-	-	-
2.5	26	23	31	28	34	31	-	-	-	-	-
4	35	31	42	37	46	41	-	-	-	-	-
6	45	40	54	48	59	54	-	-	-	-	-
10	61	54	75	66	81	74	-	-	-	-	-
16	81	73	100	88	109	99	-	-	-	-	-
25	106	95	133	117	143	130	161	141	135	182	161
35	131	117	164	144	176	161	200	176	169	226	201
50	158	141	198	175	228	209	242	216	207	275	246
70	200	179	253	222	293	268	310	279	268	353	318
95	241	216	306	269	355	326	377	342	328	430	389
120	278	249	354	312	413	379	437	400	383	500	454
150	318	285	393	342	476	436	504	464	444	577	527
185	362	324	449	384	545	500	575	533	510	661	605
240	424	380	528	450	644	590	679	634	607	781	719

Ambient temperature: 30°C

Conductor operating temperature: 90°C

1. Where a conductor operates at a temperature exceeding 70°C it must be ascertained that the equipment connected to the conductor is suitable for the conductor operating temperature (see also Regulation 512.1.2).

2. Where cables in this table are connected to equipment or accessories designed to operate at a temperature not exceeding 70°C, the current ratings given in the equivalent table for 70°C thermoplastic insulated cables (Table 4D1A) must be used (see Regulation 523.1).

The above table is in accordance with Table 4E1A of the 18th Edition of IEE Wiring Regulations BS7671 and IEC 60364-5-52.

VOLTAGE DROP

NOMINAL CROSS SECTIONAL AREA mm ²	2 CABLES DC mV/A/m	2 CABLES SINGLE-PHASE AC mV/A/m									3 OR 4 CABLES THREE-PHASE AC mV/A/m											
		Reference Methods A and B (enclosed in conduit or trunking)			Reference Methods C, F and G (clipped direct, on tray or in free air)						Reference Methods A and B (enclosed in conduit or trunking)			Reference Methods C, F and G (clipped direct, on tray or in free air)								
					Cable Touching			Cable Spaced						Cable Touching Trefoil			Cable Touching Flat			Cable Spaced* Flat		
1	46	46			46						40			40			40			40		
1.5	31	31			31						27			27			27			27		
2.5	19	19			19						16			16			16			16		
4	12	12			12						10			10			10			10		
6	7.9	7.9			7.9						6.8			6.8			6.8			6.8		
10	4.7	4.7			4.7						4			4			4			4		
16	2.9	2.9			2.9						2.5			2.5			2.5			2.5		
		r	x	z	r	x	z	r	x	z	r	x	z	r	x	z	r	x	z	r	x	z
25	1.85	1.850	0.310	1.900	1.850	0.190	1.85	1.850	0.280	1.850	1.600	0.270	1.650	1.600	0.165	1.600	1.600	0.190	1.600	1.600	0.270	1.650
35	1.35	1.350	0.290	1.350	1.350	0.180	1.35	1.350	0.270	1.350	1.150	0.250	1.150	1.150	0.155	1.150	1.150	0.180	1.150	1.150	0.260	1.200
50	0.99	1.000	0.290	1.050	0.990	0.180	1.000	0.990	0.270	1.000	0.870	0.250	0.900	0.860	0.155	0.870	0.860	0.180	0.870	0.860	0.260	0.890
70	0.68	0.700	0.280	0.750	0.680	0.175	0.710	0.680	0.260	0.730	0.600	0.240	0.650	0.590	0.150	0.610	0.590	0.175	0.620	0.590	0.250	0.650
95	0.49	0.510	0.270	0.580	0.490	0.170	0.520	0.490	0.260	0.560	0.440	0.230	0.500	0.430	0.145	0.450	0.430	0.170	0.460	0.430	0.250	0.490
120	0.39	0.410	0.260	0.480	0.390	0.165	0.430	0.390	0.250	0.470	0.350	0.230	0.420	0.340	0.140	0.370	0.340	0.165	0.380	0.340	0.240	0.420

Conductor operating temperature: 90°C

r = Resistive Component

x = Reactive Component

z = Impedance Value

* Spacings larger than one cable diameter will result in a larger voltage drop.

The above table is in accordance with Table 4E1B of the 18th Edition of IEE Wiring Regulations BS7671 and IEC 60364-5-52.

For cables having conductors of 16mm²

or less cross-sectional area their inductances can be ignored and (mV/A/m)r values only are tabulated. For cables having conductors greater than 16mm², cross-sectional area the impedance values are given as (mV/A/m)z, together with the resistive component (mV/A/m)r and the reactive component (mV/A/m)x.

The above paragraph is extracted from Appendix 4 of the 18th Edition of IEE Wiring Regulations BS7671 and IEC 60364-5-52.

DE-RATING FACTORS

AMBIENT TEMPERATURE	25°C	30°C	35°C	40°C	45°C	50°C	55°C	60°C	65°C	70°C	85°C	90°C	95°C
DE-RATING FACTOR	1.02	1.00	0.96	0.91	0.87	0.82	0.76	0.71	0.65	0.58	-	-	-

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.